



**ਦਫ਼ਤਰ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਪ੍ਰਾਂਤਕ ਉਪ ਮੰਡਲ ਲੋਕ ਨਿਰਮਾਣ ਵਿਭਾਗ,
ਭਵਨ ਤੇ ਮਾਰਗ ਸਾਖਾ, ਮੋਗਾ**

ਵੱਲ,

**Principal,
Lala Lajpat Rai International School,
Landeke, Distt, Moga.**

ਨੰਬਰ 208 ਮਿਤੀ 06-07-2026

ਵਿਸ਼ਾ :- ਸਕੂਲ ਦੀ ਇਮਾਰਤ ਸੁਰੱਖਿਅਤ ਹੋਣ ਸਬੰਧੀ ਸਰਟੀਫਿਕੇਟ ਦੇਣ ਸਬੰਧੀ ਬਾਬਤ ਸਾਲ 2026-2027

ਹਵਾਲਾ :- ਆਪ ਦਾ ਪੱਤਰ ਨੰ: LLRIS/26/05/07 ਮਿਤੀ 11-05-2026

ਉਪਰੋਕਤ ਬਿਲਡਿੰਗ ਦਾ ਨਿਰੀਖਣ ਸਬੰਧਤ ਜੂਨੀਅਰ ਇੰਜੀਨੀਅਰ ਵੱਲੋਂ ਕੀਤਾ ਗਿਆ ਅਤੇ ਇਹ ਬਿਲਡਿੰਗ ਸਾਲ 2026-27 ਲਈ ਸੁਰੱਖਿਅਤ ਪਾਈ ਗਈ ਹੈ। ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਦਾ ਸੁਰੱਖਿਅਤ ਹੋਣ ਸਬੰਧੀ ਸਰਟੀਫਿਕੇਟ ਆਪ ਨੂੰ ਮਿਤੀ 31-03-2027 ਤੱਕ ਦਾ ਜਾਰੀ ਕੀਤਾ ਗਿਆ ਹੈ। ਅੱਗੇ ਤੋਂ ਹੇਠ ਲਿਖੀਆਂ ਹਦਾਇਤਾਂ ਵੱਲ ਵਿਸ਼ੇਸ਼ ਧਿਆਨ ਦਿੱਤਾ ਜਾਵੇ :-

- 1 ਜੇਕਰ ਇਮਾਰਤ ਵਿਚ ਕੋਈ ਤਬਦੀਲੀ/ਵਧਾਇਆ ਜਾਂ ਘਟਾਇਆ ਜਾਂਦਾ ਹੈ ਤਾਂ ਕੰਮ ਕਿਸੇ ਤਕਨੀਕੀ ਇੰਜੀਨੀਅਰ ਦੀ ਦੇਖ ਰੇਖ ਵਿਚ ਹੀ ਕਰਵਾਇਆ ਜਾਵੇ, ਅਤੇ ਉਸ ਹਿੱਸੇ ਨੂੰ ਮੁਕੰਮਲ ਕਰਕੇ ਉਸ ਦਾ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਨਿਮਨ ਹਸਤਾਖਰ ਪਾਸੋਂ ਫਿਰ ਤੋਂ ਲਿਆ ਜਾਵੇ।
- 2 ਜੇਕਰ ਬਿਲਡਿੰਗ ਦੀਆਂ ਕੰਧਾਂ, ਨੀਹਾਂ ਅਤੇ ਛੱਤਾਂ ਕੁਦਰਤੀ ਆਫ਼ਤ ਕਰਕੇ ਬੈਠ ਜਾਣ ਅਤੇ ਇਸ ਸੂਰਤ ਵਿਚ ਨਿਮਨ ਹਸਤਾਖਰ ਨੂੰ ਫੌਰੀ ਤੌਰ ਤੇ ਬਿਲਡਿੰਗ ਦੀ ਹਾਲਤ ਬਾਰੇ ਸੂਚਿਤ ਕੀਤਾ ਜਾਵੇ ਅਤੇ ਨਿਰੀਖਣ ਕਰਵਾਉਣ ਉਪਰੰਤ ਹੀ ਬਿਲਡਿੰਗ ਨੂੰ ਵਰਤੋਂ ਵਿਚ ਲਿਆ ਜਾਵੇ ਜੀ।
- 3 ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਦੀ ਰਿਪੋਅਰ ਹਰ ਸਾਲ ਕਰਵਾਈ ਜਾਵੇ। ਬਿਲਡਿੰਗ ਦੀ ਹਰ ਪੱਖੋਂ ਸੇਫਟੀ ਦੀ ਸਾਰੀ ਜ਼ਿੰਮੇਵਾਰੀ ਆਪ ਦੀ ਸੰਸਥਾ/ਸਕੂਲ ਦੀ ਹੋਵੇਗੀ।
- 4 ਉਕਤ ਸਕੂਲ ਵਿਚ ਲੱਗੇ ਅੱਗ ਬੁਝਾਊ ਯੰਤਰ ਸਬੰਧੀ ਫਾਇਰ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਹਰ ਸਾਲ ਸਬੰਧਤ ਦਫ਼ਤਰ ਤੋਂ ਲੈਣ ਦੀ ਜ਼ਿੰਮੇਵਾਰੀ ਆਪ ਦੇ ਸਕੂਲ/ਸੰਸਥਾ ਦੀ ਹੋਵੇਗੀ।
- 5 ਇਹ ਸਰਟੀਫਿਕੇਟ ਕਿਸੇ ਵੀ ਲੀਗਲ ਕੇਸਾਂ ਲਈ ਪ੍ਰਮਾਣਿਤ ਨਹੀਂ ਹੋਵੇਗਾ।
- 6 ਨਿਮਨ-ਹਸਤਾਖਰ ਉਕਤ ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਦਾ 2026-2027 ਸਮੇਂ ਵੀ ਨਿਰੀਖਣ ਕਰ ਸਕਦੇ ਹਨ। ਨਿਰੀਖਣ ਦੌਰਾਨ ਕਿਸੇ ਕਿਸਮ ਦੀ ਕੋਈ ਅਣਗਹਿਲੀ ਪਾਈ ਗਈ ਤਾਂ ਬਿਨਾਂ ਕੋਈ ਨੋਟਿਸ ਦਿੱਤੇ ਜਾਰੀ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਰੱਦ ਕੀਤਾ ਜਾ ਸਕਦਾ ਹੈ।
- 7 ਡਾਇਰੈਕਟਰ ਜਰਨਲ ਸਕੂਲ ਸਿੱਖਿਆ ਵਿਭਾਗ ਪੰਜਾਬ ਸਟੇਟ ਪ੍ਰੋਜੈਕਟ ਸਰਵ ਸਿੱਖਿਆ ਅਭਿਆਨ ਦੇ ਪੱਤਰ ਨੰ: 75444 ਮਿਤੀ 06-11-2009 ਮੁਤਾਬਿਕ ਸਕੂਲ ਵਿਚ ਅੱਗ ਬੁਝਾਊਣ ਵਾਲੇ ਯੰਤਰ ਚਾਲੂ ਹਾਲਤ ਵਿਚ ਰੱਖੇ ਜਾਣ ਕਿਸੇ ਵੀ ਅਣਸੁਖਾਵੀ ਦੁਰਘਟਨਾ ਦੀ ਸਾਰੀ ਜ਼ਿੰਮੇਵਾਰੀ ਸਬੰਧਤ ਸਕੂਲ ਦੀ ਹੋਵੇਗੀ।
- 8 ਅਗਲੇ ਸਾਲ 2027-28 ਦੀ ਇੰਸਪੈਕਸ਼ਨ ਕਰਾਉਣੀ ਯਕੀਨੀ ਬਣਾਈ ਜਾਵੇ।

ਨੱਥੀ/ਸਰਟੀਫਿਕੇਟ।

men
ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ,
ਪ੍ਰਾਂਤਕ ਉਪ ਮੰਡਲ ਭ ਤੇ ਮ ਸਾਖਾ,
ਮੋਗਾ।

PROFORMA FOR SAFETY OF SCHOOL BUILDING

PART-I

(To be filled by the Head of School / Institute)

- 1) Name of the School **LALALAPAT RAI INTERNATIONAL SCH**
- 2) Location. **Amritsar Road Kandeke Moga**
- 3) Plot Area.
- 4) Total Covered Area. **14441 Sqmtr**
- 5) Number of storey's **- 2**
- 6) Year of construction of Building **2008**
- 7) If the building has been constructed under the Supervision of the qualified Engineer, the following details may be given:-
 - a) Name of the Engineer with Qualification. **Hardeep - Suler**
 - b) Address of Engineer.
 - c) Set of structural drawing used in the construction, Available.
 - d) Name & address of Architect with qualification : **Harvey Builders' Planner (MC)**
- 8) Whether the building has been constructed for the Purpose school. : **Yes / No**
Residential purpose and converted for use as a school : **Yes / No**
- 9) Material used for Roof. : **Yes / No**
 - a) R.C.C slab / R.B.C Slabs : **Yes / No**
 - b) R S Joist & Battens : **Yes / No**
 - c) Wooden Joist & Battens : **Yes / No**
- 10) Material used for walls. : **Yes / No**
 - a) Mud Mortar. : **Yes / No**
 - b) Cement Mortar. : **Yes / No**
 - c) Lime Mortar. : **Yes / No**
- 11) Flooring. : **Yes / No**
 - a) Conglomerate : **Yes / No**
 - b) Terrazzo. : **Yes / No**
 - c) Brick Paving : **Yes / No**
- 12) A detailed drawing indicating dimension of Room Alongwith size and location of doors and windows (attached).
- 13) For Fire Safety. : **Yes / No**
 - a) Weather the width of the staircase is 1.5 Mtr. : **Yes / No**
 - b) Weather portable fire exiting. : **Yes / No**
 - c) Weather School building is free from inflammable & toxic material : **Yes / No**
 - d) Weather r Cooking of food is done at a safe place : **Yes / No**
 - e) Weather any thatch of combustible material as been Used. : **Yes / No**

14) Requirement for fire Protection Arrangements under NBC

Part -IV

(For Building height Less than 15.454metre)

Yes

- / No
- a) Weather house Real provided. : Yes / No
- b) Weather down corner provided. : Yes / No
- c) Weather automatic sprinkler provided. : Yes / No
- d) Weather underground static water storage tank of : Yes / No
Capacity 50,000Ltr. (It converted are excess 1600sqm)
- e) Weather r over head tank of capacity 10,000 Ltr. : Yes/ No
Exists. (in case of house real) 20,000 Ltr.
- f) Weather one electric and one diesel pump of 3 kg/ cum : Yes/No
Pressure of capacity 1620 LPM. One electric pump of
Capacity 180LPM exist near underground static tank.
- g) Weather a pump 3 Kg cum preasur & 450 500 LPM : Yes/ No
Exist near over head tank.

PART -II

(To be filled by the S.D.E for PWD (B&R) Department)

School stamp

Director
Lala Lajpat Rai International School
Moga

- a) I have visited the above mentioned school on date 8-06-2021 and have visually inspected it from all angles of safety and found it fit for normal use as school building.
- b) In case any addition / alteration or expansion and modifications to this building is to be carried out, the same be carried out under the supervision of a qualified Engineer and this certificate may be re-obtained after the completion from the undersigned.
- c) In case the building is affected by flood, or if there is settlement of walls foundation and sagging of roofs etc., immediate inspection of the undersigned be arranged to check the stability and safety of the building.
- d) This building can be safely occupied for normal use upto (indicate upto which it can be used) Valid up to 31-03-2027

Principal Engineer.
Principal Sub Division.
Moga.

ANNEXURE D

BUILDING SAFETY CERTIFICATE

Ref. No. _____

Dated: _____

It is certified that the existing building of Lala Lajpat Rai International, School at Amritsar Road, Near Savera Hospital, Landke (Distt. Moga) is having block(s)/ Floor(s) as per details below:

Details of Block (s) in school	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No. of floor(s) in the Block	02	02	0	0	0	0

The building is owned by Lala Lajpat Rai International School, Landeke (Moga) have complied with the Building Safety requirements in accordance with National Building code Rules. and verified by the Junior Engineer, Provincial Sub Division, PWD (B&R) Branch, Moga on _____ in the presence of Mrs. Dr. Poonam Arora, Principal of the school and that the building/ premises is fit for occupancy for running school with effect from 01/04/2025 for a period of one year in accordance with rule and subject to compliance of the specific conditions as appended.

1. In case any addition/ alteration or expansion and modifications to this building is to be carried out, the same be carried out under the supervision of a qualified Engineer and this certificate may be re-obtained after the completion from the undersigned.
2. In case the building is affected by flood, or if there is settlement of walls/ foundation and sagging of roofs etc. immediate inspection of the undersigned be arranged to check the stability and safety of the building.
3. Building repairing to be done every year. Safety of the school building from every corner is the full responsibility of the school.
4. It is the responsibility of the school to get Fire Safety Certificate for its fire extinguishers every year.
5. This certificate is not for any legal purpose.
6. The undersigned can inspect the school any time during the session 2025-26. The Building Safety Certificate can be cancelled, if any discrepancy is found.
7. According to the letter No.75444 dated 06/11/2009 issued by the Director General Schools Education Department, Punjab, the fire extinguishers in the school must be in working condition to control over any type of mishap.
8. Inspection be ensured for the next session i.e. 2026-27.

Issued on 06-07-2026 at Moga by

Signature with Seal: _____

men
 Sub Divisional Engineer
 Provincial Sub Division
 PWD (B&R) B. Moga

Name: _____